



1. Palm
2. Conductor wire rod
3. Composite insulation
4. Filling fluid
5. Stress cone
6. End bell
7. Composite post insulator
8. Earthing point



- Note:
1. Mass:150kg approx.
2. Dimensions in mm.
3. The dotted line indicates the bracket and is not included in the product.
4. The thickness of palm is 14mm or 21mm.



DESIGN	Wu Jiaqi	DATE	2023.6.9	COMPANY NAME	
DWN	Wu Jiaqi	DATE	2023.6.9	Angelor(Jiangsu)Intelligent Electric Co. Ltd.	
CHK	Zhang Haitao	DATE	2023.6.12	NAME	
APVD	Zhang Haitao	DATE	2023.6.12	110kV Composite insulation outdoor termination	
DRAWING MARK		MASS	SCALE	DRAWING NUMBER	
		150.00kg	1:11	YJZW FY4 64/110	
VERSION NUMBER: Rv.01		REVISION NUMBER: -			